



## WASTEWATER TECHNOLOGY TRAINERS

*Transforming today's operators into tomorrow's water quality professionals*

---

### Problem of the Day 2014.Dec.31

#### Introduction

The Chinese character meaning “crisis” is two characters superimposed on each other. The first, taken by itself, means “danger.” The second, taken by itself, means “opportunity.” With the drought in California, we have certainly been in crisis mode. But what amazing opportunity! **It is a good time to be in the water business.** We can live without oil but **it's impossible to live without water.**

But the water business is getting more and more sophisticated. So much of protecting environmental and public health rests on the shoulders of water and wastewater treatment plant operators. We also must do our jobs as cost effectively as possible to protect our ratepayers' hard earned money. Our jobs aren't just about “meeting permit.” Consider this, or something like it, as the professional operator's credo:

**The mission of wastewater treatment plant operators is to remove pollutants from the incoming water while complying with all permit requirements—water, land and air—and convert them to safe disposable biosolids as sustainably and cost effectively as possible.**

How do we prove to our ratepayers, regulators and ourselves that we're up for the task: **by attaining increasing levels of certification.**

At the heart of wastewater treatment is **nutrient and pathogen removal.** Let's talk about nutrients. Today when we hear “nutrients,” most of us think about nitrogen (N) and phosphorus (P), but there is a third nutrient that has defined wastewater treatment from the beginning: carbon (C). Yes, carbon. The massive, indiscriminate release of carbon into our waterways—specifically, organic carbon—during the 100+ years leading up to the passage of the Clean Water Act in 1972 in the United States didn't lead to the algae blooms and eutrophication we associate with N and P pollution. Instead, the oxidation of all that carbon by resident aquatic microorganisms led to dissolved oxygen (DO) “sag,” and fish suffocated. And rivers caught on fire.

We indirectly measure the presence, or absence, of organic carbon by a number of analytical tests: BOD, CBOD, COD, TOC (total organic carbon), VSS and VS. All of these tests measure “organics” in a sample. “Organic” is synonymous with “organic carbon.”

Primary clarifiers remove more organics for less money than any other process unit at a wastewater treatment plant. The process objective of primary clarification is the removal of settleable total suspended solids (TSS<sub>set</sub>). The BOD (or COD) associated with those solids is removed when the solids are removed. This is important. The reason it is important is because secondary treatment, where the remaining BOD is “removed” (I will explain “removed” in a subsequent post), is expensive, so **the more BOD removed in the primary clarifiers, the better.**

Indeed, wastewater treatment **is** expensive but it is our job to treat wastewater “as cost effectively as possible.” The organic carbon captured by primary clarifiers can be converted to methane in anaerobic digesters that can then be combusted in engines driving electrical generators. Augmenting the organic carbon captured in primary clarifiers, some plants feed fats, oils and grease (FOG) to their digesters to increase methane production and electricity generation. East Bay Municipal Utilities District (EBMUD) has been so successful doing so, they produce more electricity than they use. **This is the future.**

For those of you who may be new to WWTT's Problem of the Day, we insert a page break before and after the problem statement so you can print it without looking at the solution. **See what you can do to solve the problem before looking at the solution.**

### **Problem of the Day**

The Running Springs wastewater treatment plant receives an average dry weather flow of 2.5 MGD. The peak wet weather flow is 8 MGD. There are two primary clarifiers, each is 60 feet in diameter with an average depth of 16.5 feet. There is a single effluent weir around the periphery of each primary clarifier. The average influent TSS and BOD concentrations during dry weather flow are 325 and 350 mg/L, respectively. The influent TSS are 72% volatile. The average primary effluent TSS and BOD concentrations during dry weather flow are 105 and 205 mg/L, respectively. Each primary sludge pump pumps 30 gpm. Find the detention time if only one primary clarifier is on line during dry weather flow.

## Discussion

Because primary clarifiers are such treatment plant workhorses, operators really need to “get their heads around them.” We’re going to use this same problem statement and do every primary clarifier type problem we can think of, maybe even make up a few! We’ll keep track of the types of problems in the following list so you can refer back to individual Problems of the Day if you have a question on a specific type of primary clarifier problem.

- ✦ 2014.Dec.16—TSS removal efficiency
- ✦ 2014.Dec.17—BOD removal efficiency
- ✦ 2014.Dec.18—VSS removal efficiency
- ✦ 2014.Dec.19—influent VSS concentration
- ✦ 2014.Dec.20—primary effluent VSS concentration
- ✦ 2014.Dec.21—primary sludge volatile content (VS and VSS)
- ✦ 2014.Dec.22—influent TSS pounds per day
- ✦ 2014.Dec.23—influent VSS pounds per day
- ✦ 2014.Dec.24—influent BOD pounds per day
- ✦ 2014.Dec.25—happy holidays
- ✦ 2014.Dec.26—TSS pounds per day removed
- ✦ 2014.Dec.27—VSS pounds per day removed
- ✦ 2014.Dec.28-30—Surface over flow rate (SOR)
- ✦ 2014.Dec.31—Detention time

**In today’s problem we are asked to calculate the primary clarifier detention time.** The detention time is an important design and operational consideration for all clarifiers: if it is too short, performance would be expected to deteriorate because of high flow velocity and insufficient time for settling if it is too long, especially in primary clarifiers, the water and sludge may go septic causing odors and other problems. Typically, the detention time in primary clarifiers is 1 to 3 hours. All operators should know that clarifier detention times are expressed in hr. On certification exams, the State may not specifically ask for the clarifier detention time to be expressed in hours, but this is something operators should know.

Wastewater treatment plant operators often have to calculate how long it takes to fill a tank or a reservoir, how long it takes to empty a tank or a reservoir, or what the detention time is in a tank or a reservoir.

**Whenever a question arises asking about time (T) and includes volume (V) and flow rate (Q), the equation will almost always be the same:**

$$T = \frac{V}{Q}$$

Repeat for emphasis, **this is the equation that will be used for every question asking about fill time, empty time or detention time.** All that is needed to do the calculation is the volume and flow rate and the units required in the answer. And sometimes questions will arise that ask to find volume given time and flow rate, or to find flow rate given time and volume. **Same equation.**

## Solution

The units needed in the answer, **hr**, are shown between heavy vertical lines followed by the equals sign and the blank track to get the problem started.

**Problem of the Day:** The Running Springs wastewater treatment plant receives an average dry weather flow of 2.5 MGD. The peak wet weather flow is 8 MGD. There are two primary clarifiers, each is 60 feet in diameter with an average depth of 16.5 feet. There is a single effluent weir around the periphery of each primary clarifier. The average influent TSS and BOD concentrations during dry weather flow are 325 and 350 mg/L, respectively. The influent TSS are 72% volatile. The average primary effluent TSS and BOD concentrations during dry weather flow are 105 and 205 mg/L, respectively. Each primary sludge pump pumps 30 gpm. Find the detention time if only one primary clarifier is on line during dry weather flow.

Information summary, specifically labeled (**bold** indicates used in today's problem):

- **Average dry weather flow = 2.5 Mgal/d**
- Peak wet weather flow = 8 Mgal/d
- **Number of primary clarifiers = 2 PC (only one is on line)**
- **Primary clarifier diameter = 60 ft**
- **Primary clarifier depth = 16.5 ft**
- Primary influent dry weather TSS = 325 mg TSS/L
- Primary influent dry weather BOD = 350 mg BOD/L
- Primary influent TSS = 72% VSS = 72 mg VSS/100 mg TSS
- Primary effluent dry weather TSS = 105 mg TSS/L
- Primary effluent dry weather BOD = 205 mg BOD/L
- Primary sludge pumps, each = 30 gal sldg/min
- Calculate: **the detention time with one on-line primary clarifier during dry weather.**

	hr		=	_____
--	----	--	---	-------

As discussed above, whether the question asks for fill time, empty time or detention time, the equation is going to be the same:

$$T = \frac{V}{Q}$$

The railroad track is started, therefore, by entering volume (0.785 x diameter<sup>2</sup> x depth) in the numerator and flow (dry weather flow in this case) in the denominator.

	hr		=	<table border="1" style="display: inline-table; border-collapse: collapse;"> <tr> <td style="padding: 2px 5px;">0.785</td> <td style="padding: 2px 5px;">60 ft</td> <td style="padding: 2px 5px;">60 ft</td> <td style="padding: 2px 5px;">16.5 ft</td> <td style="padding: 2px 5px;">d</td> </tr> <tr> <td colspan="4" style="text-align: center; padding: 2px 5px;">PC</td> <td style="padding: 2px 5px;">2.5 Mgal</td> </tr> </table>	0.785	60 ft	60 ft	16.5 ft	d	PC				2.5 Mgal		_____
0.785	60 ft	60 ft	16.5 ft	d												
PC				2.5 Mgal												

There is only one primary clarifier (PC) on line in this question, so it is a simple matter to cancel the PC unit in the denominator.

	hr		=	<table border="1" style="display: inline-table; border-collapse: collapse;"> <tr> <td style="padding: 2px 5px;">0.785</td> <td style="padding: 2px 5px;">60 ft</td> <td style="padding: 2px 5px;">60 ft</td> <td style="padding: 2px 5px;">16.5 ft</td> <td style="padding: 2px 5px;">d</td> <td style="padding: 2px 5px;">1 PC</td> </tr> <tr> <td colspan="4" style="text-align: center; padding: 2px 5px;">PC</td> <td style="padding: 2px 5px;">2.5 Mgal</td> <td style="padding: 2px 5px;"></td> </tr> </table>	0.785	60 ft	60 ft	16.5 ft	d	1 PC	PC				2.5 Mgal			_____
0.785	60 ft	60 ft	16.5 ft	d	1 PC													
PC				2.5 Mgal														

The unit, **d**, in the numerator needs to be converted to the unit, **hr**, needed in the answer. This is done using the very well known conversion factor, **24 hr/d**.

	hr		=	<table border="1" style="display: inline-table; border-collapse: collapse;"> <tr> <td style="padding: 2px 5px;">0.785</td> <td style="padding: 2px 5px;">60 ft</td> <td style="padding: 2px 5px;">60 ft</td> <td style="padding: 2px 5px;">16.5 ft</td> <td style="padding: 2px 5px;">d</td> <td style="padding: 2px 5px;">1 PC</td> <td style="padding: 2px 5px;">24 hr</td> </tr> <tr> <td colspan="4" style="text-align: center; padding: 2px 5px;">PC</td> <td style="padding: 2px 5px;">2.5 Mgal</td> <td style="padding: 2px 5px;"></td> <td style="padding: 2px 5px;">d</td> </tr> </table>	0.785	60 ft	60 ft	16.5 ft	d	1 PC	24 hr	PC				2.5 Mgal		d		_____
0.785	60 ft	60 ft	16.5 ft	d	1 PC	24 hr														
PC				2.5 Mgal		d														

In order to convert  $\text{ft}^3$  (ft x ft x ft) to **gal**, we first need to convert **Mgal** to **gal** using the conversion factor, **Mgal/10<sup>6</sup> gal**.

hr	=	0.785	60 ft	60 ft	16.5 ft	d	1 PG	24 hr	Mgal	
		PG					2.5 Mgal		d	10 <sup>6</sup> gal

Now the well know conversion factor, **7.48 gal/ft<sup>3</sup>**, is used to cancel unwanted units.

hr	=	0.785	60 ft	60 ft	16.5 ft	d	1 PG	24 hr	Mgal	7.48 gal
		PG					2.5 Mgal		d	10 <sup>6</sup> gal

In the railroad track we now have only the units needed in the answer, **hr**, so we **know** the math is done.

**Problem of the Day:** The Running Springs wastewater treatment plant receives an average dry weather flow of 2.5 MGD. The peak wet weather flow is 8 MGD. There are two primary clarifiers, each is 60 feet in diameter with an average depth of 16.5 feet. There is a single effluent weir around the periphery of each primary clarifier. The average influent TSS and BOD concentrations during dry weather flow are 325 and 350 mg/L, respectively. The influent TSS are 72% volatile. The average primary effluent TSS and BOD concentrations during dry weather flow are 105 and 205 mg/L, respectively. Each primary sludge pump pumps 30 gpm. Find the detention time if only one primary clarifier is on line during dry weather flow.

Information summary, specifically labeled (**bold** indicates used in today's problem):

- **Average dry weather flow = 2.5 Mgal/d**
- Peak wet weather flow = 8 Mgal/d
- **Number of primary clarifiers = 2 PC**
- **Primary clarifier diameter = 60 ft**
- **Primary clarifier depth = 16.5 ft**
- Primary influent dry weather TSS = 325 mg TSS/L
- Primary influent dry weather BOD = 350 mg BOD/L
- Primary influent TSS = 72% VSS = 72 mg VSS/100 mg TSS
- Primary effluent dry weather TSS = 105 mg TSS/L
- Primary effluent dry weather BOD = 205 mg BOD/L
- Primary sludge pumps, each = 30 gal sldg/min
- Calculate: **the detention time with one on-line primary clarifier during dry weather.**

hr	=	0.785	60 ft	60 ft	16.5 ft	d	1 PG	24 hr	Mgal	7.48 gal
		PG					2.5 Mgal		d	10 <sup>6</sup> gal

The arithmetic gives the answer:

$$0.785 \times 60 \times 60 \times 16.5 \times 1 \times 24 \times 7.48 \div 2.5 \div 1,000,000 = \underline{\underline{3.3 \text{ hr}}}$$

This detention time is just a little longer than desired. The operator's strategy of using only one primary clarifier during dry weather is the right strategy.

**Happy calculating. Let us know, by leaving a comment, if you want us to do a specific problem or if you see a mistake.**